

**FIRE PROTECTION PIPE WRAPS (OO)**


- **Application:** designed for fire preventive insulation of passages:
  - flammable pipes,
  - steel and copper pipes isolated with synthetic foam cover, through separations of fire division.
- **Installation:**
  - in walls - one band in the wall axis, - in floors - one band inside the floor should be placed 1 cm above the bottom floor edge. Free spaces between the band and the wall (floor) should be filled with a cement or plaster grout. Detailed rules of installation and range of applications are defined in the Technical Approval.
  - In order to undergo training and obtain a Contractor Licence, one has to contact representatives of Niczuk Metall-PL.

External pipe diameter [mm]	Dimensions A x g [mm] L [mm] K [mm]			Mass [kg]	Designation for the order	Part number
50□	290	210	60x6,0	0,10	OO-50	0610005005
82	370	290	60x6,0	0,14	OO-82	0610008205
110	458	388	60x9,5	0,27	OO-110	0610011005
125	540	450	60x9,5	0,70	OO-125	0610012505
160	683	583	100x11,4	0,88	OO-160	0610016005

**FIRE PROTECTION PIPE WRAPS (OO)**
